

INSTALLATION INSTRUCTIONS

Issue No: SEPTEMBER 2011

WEATHERLUX LED PICTO EXIT BODY

PLEASE READ THESE INSTALLATION INSTRUCTIONS CAREFULLY BEFORE INSTALLING OR MAINTAINING THIS EQUIPMENT. THE PRODUCT IS DESIGNED FOR INSTALLATION AND MAINTENANCE IN ACCORDANCE WITH RELEVANT AUSTRALIAN STANDARDS (AS/NZ3000), THESE INSTRUCTIONS AND LOCAL REGULATIONS (WHERE APPLICABLE), BY AN AUTHORISED AND LICENCED ELECTRICIAN.

THE INSTALLATION INSTRUCTIONS WERE CORRECT AT THE TIME OF PRINT. TO REFLECT CHANGES IN TECHNOLOGY AND AUSTRALIAN STANDARDS; PIERLITE AUSTRALIA RESERVES THE RIGHT TO AMEND THE INSTRUCTIONS WITHOUT NOTICE. UPDATED GUIDELINES CAN BE FOUND ON www.pierlite.com.

IMPORTANT - THE PRODUCT MUST BE MAINTAINED AND OPERATED IN ACCORDANCE WITH THE MANUFACTURER'S INSTRUCTIONS, FAILURE TO DO SO MAY DAMAGE THE PRODUCT AND SERVICES. IT IS STRONGLY RECOMMENDED THAT THIS IMPORTANT NOTE BE COMMUNICATED TO THE OWNER AND OR OPERATOR OF THE INSTALLATION AT THE TIME OF SITE COMMISSIONING.

FOR THE LATEST PRODUCT MAINTENANCE GUIDES PLEASE GO TO www.pierlite.com.

PIERLITE AUSTRALIA IS NOT RESPONSIBLE FOR ANY PRODUCT NOT MAINTAINED IN ACCORDANCE WITH THE RECOMMENDED PROCEDURES.

FOR RECOMMENDED LAMP MAINTENANCE GUIDES, PLEASE REFER TO THE LAMP INSTALLATION GUIDELINES SUPPLIED WITH THE LAMP PRODUCT OR THE NOMINATED LAMP MANUFACTURER'S WEBSITE.

1. PRODUCT SPECIFICATION:

Type of Protection	Class 2 Luminaire
IP Rating	IP65
Nominal Voltage	240V
Circuit wattage	4.9W
Line current	0.623A
Power factor	0.8
Nominal Freq. (Hz)	50 Hz
Rated Maximum Ambient Temperature	40°C
Suitable for direct mounting on flammable surfaces	NO

2. APPROVALS:

The C-Tick marking of this product applies to AS/NZS CISPR15:2006 "Limits and methods of measurement of radio disturbance characteristics of electrical lighting and similar equipment". This product is designed to conform to AS/NZS60598 "Luminaires, general requirements and tests".



3. STORAGE: Luminaires are to be stored in cool and dry conditions.

4. APPLICATION:

The installation application and orientation of the product is designed in accordance with the nominated product IP rating, class designation and these installation instructions. Installation environments outside these conditions is not recommended.

5.0 INSTALLATION:

Installation of the product is to be completed by an authorized and licenced electrician, in accordance with these instructions, relevant Australia standards and local regulations (where applicable).

For electronic control equipment (when supplied) DO NOT MEGGER between A and N. All cable terminations must be installed in accordance with the designated IP rating of the product.

Mount Weatherlux LED Exit body to the wall or ceiling and connect as per Australian Standards, choose appropriate wall or ceiling mount Weatherlux diffuser and secure with screws supplied.

6 LAMPS:

The product is designed with the supplied lamp/s and it is strongly recommended that any lamp changes be made in accordance with the type, colour and brand supplied. Pierlite Australia is not responsible for the product performance of alternative lamp/s used.

7 MAINTENANCE

The supply must be isolated before opening or accessing the luminaire.

Product maintenance is IMPORTANT and is critical to the products designed performance.

The product is to be maintained in accordance with the manufacturer's instructions. For the latest product maintenance guides please go to www.pierlite.com. Pierlite Australia is not responsible for any product not maintained in accordance with the recommended procedure or intervals.

For products supplied with glass visors or covers, do not operate the product with a damaged visor or cover; it is recommended the product be turned off, area surrounding the product vacated and the damaged glass replaced by a professional installer immediately.

